

Date	Observed inflow in diversion structure - Avg (m3/s)	Minimum inflow observed during lean season in the diversion structure	Flow immediately D/S of Diversion Structure					Remarks
			Required to be released as per Notification by the State Govt.	Flow released through BTRDT, Radial Gates	Flow released through SFT	Net Flow released	Shortfall if any with reason	
01-03-2013	66	54	8.1	7.6	0.625	8.22	Nil	
02-03-2013	68	54	8.1	7.6	0.625	8.22	Nil	
03-03-2013	77	54	8.1	7.6	0.625	8.22	Nil	
04-03-2013	69	54	8.1	7.6	0.625	8.22	Nil	
05-03-2013	70	54	8.1	7.6	0.625	8.22	Nil	
06-03-2013	76	54	8.1	7.6	0.625	8.22	Nil	
07-03-2013	74	54	8.1	7.6	0.625	8.22	Nil	
08-03-2013	77	54	8.1	7.6	0.625	8.22	Nil	
09-03-2013	76	54	8.1	7.6	0.625	8.22	Nil	
10-03-2013	73	54	8.1	7.6	0.625	8.22	Nil	
11-03-2013	85	54	8.1	7.6	0.625	8.22	Nil	
12-03-2013	85	54	8.1	7.6	0.625	8.22	Nil	
13-03-2013	82	54	8.1	7.6	0.625	8.22	Nil	
14-03-2013	78	54	8.1	7.6	0.625	8.22	Nil	
15-03-2013	75	54	8.1	7.6	0.625	8.22	Nil	
16-03-2013	75	54	8.1	7.6	0.625	8.22	Nil	
17-03-2013	69	54	8.1	7.6	0.625	8.22	Nil	
18-03-2013	86	54	8.1	7.6	0.625	8.22	Nil	
19-03-2013	85	54	8.1	7.6	0.625	8.22	Nil	
20-03-2013	88	54	8.1	7.6	0.625	8.22	Nil	
21-03-2013	93	54	8.1	7.6	0.625	8.22	Nil	
22-03-2013	98	54	8.1	7.6	0.625	8.22	Nil	
23-03-2013	90	54	8.1	7.6	0.625	8.22	Nil	
24-03-2013	82	54	8.1	7.6	0.625	8.22	Nil	
25-03-2013	105	54	8.1	7.6	0.625	8.22	Nil	
26-03-2013	116	54	8.1	7.6	0.625	8.22	Nil	
27-03-2013	80	54	8.1	7.6	0.625	8.22	Nil	
28-03-2013	105	54	8.1	7.6	0.625	8.22	Nil	
29-03-2013	109	54	8.1	7.6	0.625	8.22	Nil	
30-03-2013	89	54	8.1	7.6	0.625	8.22	Nil	
31-03-2013	88	54	8.1	7.6	0.625	8.22	Nil	

Nagaraj
Sr. Manager (O&M)
NJHPS, Nathpa

~~AGM/T/c~~
NJHPS, Nathpa